



Certificate / Certificat Zertifikat / 合格証

DET 1106064 C001

exida hereby confirms that the:

Eagle Quantum Premier (EQP) Safety System

**Detector Electronics Corporation
Minneapolis, MN - USA**

Has been assessed per the relevant requirements of:

IEC 61508 : 2010 Parts 1-7

and meets requirements providing a level of integrity to:

Systematic Capability: SC 2 (SIL 2 Capable)

Random Capability: Type B Element

SIL 2 @ HFT=0; Route 1_H

**PFD_{AVG} and Architecture Constraints
must be verified for each application**

Safety Function:

The EQP Safety System detects flame, gas, smoke or other programmed hazardous condition and energizes an output per the programmed logic.

Application Restrictions:

The unit must be properly designed into a Safety Instrumented Function per the Safety Manual requirements.



John C. Yozallinas
Evaluating Assessor

[Signature]
Certifying Assessor

The manufacturer
may use the mark:



Revision 1.14 July 15, 2019
Surveillance Audit Due
September 1, 2019



ISO/IEC 17065
PRODUCT CERTIFICATION BODY
#1004

Certificate / Certificat / Zertifikat / 合格証

DET 1106064 C001

Systematic Capability: SC 2 (SIL 2 Capable)

Random Capability: Type B Element

SIL 2 @ HFT=0; Route 1_H

**PFD_{AVG} and Architecture Constraints
must be verified for each application**

Systematic Capability:

The Product has met manufacturer design process requirements of Safety Integrity Level (SIL) 2. These are intended to achieve sufficient integrity against systematic errors of design by the manufacturer.

A Safety Instrumented Function (SIF) designed with this product must not be used at a SIL level higher than stated.

Random Capability:

The SIL limit imposed by the Architectural Constraints must be met for each element.

IEC 61508 Failure Rates in FIT (1 FIT = 1 failure / 10⁹ hours)

Device	λ_{sd}	λ_{su}	λ_{dd}	λ_{du}	SFF
EQ300X – common	0	32	2175	88	96%
EQ3730EDIO – common	0	88	459	21	96.3%
EQ3730EDIO – per Input monitored for open and shorts	0	11	53	1	n/a
EQ3730EDIO – per Input monitored for open only	0	11	47	7	n/a
EQ3730EDIO – per monitored output	0	0	62	1	n/a
X3301 – Multispectrum IR Flame Detector with EQPSL comm.	0	104	1545	55	96.7%
PIRECL – Eclipse Infrared Gas Detector with EQPSL comm.	0	72	2894	147	95%
AIM – common	0	45	463	11	97.8%
AIM – per Input channel	0	0	26	4	n/a
UD10 EQP	89	43	512	80	n/a
LS2000 EQPSL	367	57	1320	59	96.7%
EQ3760ASM Smoke and Heat Module	386	191	743	56	95.9%
EQ3780HSDM High Speed Deluge Module	7761	694	3134	385	96.7%

SIL Verification:

The Safety Integrity Level (SIL) of an entire Safety Instrumented Function (SIF) must be verified via a calculation of PFD_{avg} considering redundant architectures, proof test interval, proof test effectiveness, any automatic diagnostics, average repair time and the specific failure rates of all products included in the SIF. Each element must be checked to assure compliance with minimum hardware fault tolerance (HFT) requirements.

The following documents are a mandatory part of certification:

Assessment Report: DET 11-06-064 R002 V1R11

Safety Manual: 95-8599-10.1, or later

Eagle Quantum
Premier (EQP)
Safety System



80 N Main St
Sellersville, PA 18960